

# ASTA CERTIFICATION SERVICES

(Incorporated in the year 1938)

ASTA House, Chestnut Field, Rugby, CV21 2TL, England

**CERTIFICATE OF TYPE TEST**

Laboratory Ref. No. 101945AC

**APPARATUS:** Two ring-type 0.66/3/- kV (Um/Insulation level), 50 Hz, cast resin current transformers comprising one single-ratio 2500/5 A measuring current transformer and one single-ratio 2250/5 A protective current transformer.

**DESIGNATION:** NITECH Current Transformers  
2500/5A Type EMR-130 and 2250/5A Type EPR-110

**MANUFACTURER:** Dixon Industrial (s) Pte Ltd  
No.32 Ang Mo Kio Industrial Park 2, #03-12,  
Sing Industrial Complex,  
Singapore 569510

**TESTED BY:** Testing & Certification Australia  
18 Mars Road Lane Cove NSW 2066 Australia

**DATE(S) OF TESTS:** 13 December 2004 to 5 January 2005

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with

IEC Publication 60044-1 : 2003 Consolidated Edition 1.2 and BSEN 60044-1 : 1999 with Amendments No. 1 and 2, Clauses 7.1, 7.2, 8.3, 8.4, 11.4, 12.4 and 12.5

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated below.

|   |                                  |
|---|----------------------------------|
| <b>Rated short-time thermal and dynamic current</b> (Clause 7.1)  | : 63 kA for 3 s, 158 kA peak     |
| <b>Rated continuous thermal current</b> (Clause 7.2)  | : Equal to rated primary current |
| <b>Power-frequency withstand and Inter-turn overvoltage tests</b><br>(Clauses 8.3 and 8.4)  | : Complied                       |
| <b>Accuracy of measuring current transformers</b> (Clause 11.4)<br>2500/5   | : Class 1 M                      |
| <b>Current error, phase displacement and composite error of protective current transformers</b> (Clauses 12.4 and 12.5)<br>2250/5 | : Class 5P20                     |

The record of Proving Tests applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

This Certificate comprises 11 pages, 1 diagram, 1 oscillogram, 6 photographs, 4 drawings and no other sheets, as detailed on page 1.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any page(s) on which are stated the assigned rated characteristics of the apparatus tested, are permitted without written permission from ASTA Certification Services, ASTA House, Chestnut Field, Rugby, CV21 2TL England. (see overleaf)



010

*M. A. Carstedt* M. A. Carstedt  
ASTA Observer

*C. Nick-Jones*  
DIRECTOR

*8th February 2005* Date

# Record Of Proving Tests

# ASTA

Laboratory Reference No: 101945

## CONTENTS

|                 |   |                             |                      |
|-----------------|---|-----------------------------|----------------------|
| Test Record     | : | Pages 1 to 11               |                      |
| Diagram         | : | Figure 1                    |                      |
| Oscillogram No. | : | 8222.002                    |                      |
| Photographs No. | : | 24116 / B, H, L, M, R and S |                      |
| Drawings No.    | : | 2250/5 1 of 2               | Original 25 Oct 2004 |
|                 |   | 2250/5 2 of 2               | Original 25 Oct 2004 |
|                 |   | 2500/5 1 of 2               | Original 25 Oct 2004 |
|                 |   | 2500/5 2 of 2               | Original 25 Oct 2004 |

## APPARATUS TESTED

Two ring-type 0.66/3/- kV\* (Um/Insulation level), 50 Hz, cast resin current transformers without primary conductor and primary insulation, comprising one single-ratio 2500/5 A measuring current transformer and one single-ratio 2250/5 A protective current transformer.

Designated by the client as NITECH Current Transformers 2500/5A Type EMR-130 and 2250/5A Type EPR-110.

Two samples of each CT ratio were submitted for the tests.

| Item # | Ratio  | Class | Rated burden<br>VA | Serial number | Rated primary current<br>A | Secondary winding cross-sectional area<br>mm <sup>2</sup> | Secondary resistance at 75°C<br>Ω |
|--------|--------|-------|--------------------|---------------|----------------------------|---|-----------------------------------|
| 1      | 2500/5 | 1     | 30                 | 019742        | 2500                       | 2.0   | 0.3407                            |
| 2      | 2500/5 | 1     | 30                 | 019743        | 2500                       | 2.0   | 0.3419                            |
| 3      | 2250/5 | 5P20  | 15                 | 050573        | 2250                       | 2.0   | 0.6365                            |
| 4      | 2250/5 | 5P20  | 15                 | 050574        | 2250                       | 2.0   | 0.6338                            |

The manufacturer has assigned a rated short-time thermal current for the 2500/5 and 2250/5 current transformers of 63 kA rms for 3 s, and a rated dynamic current of 158 kA peak, with secondary windings short-circuited.

The secondary winding conductors are enamel insulated copper wire.

The core and secondary winding are encapsulated in epoxy resin insulation.

\* The dash indicates the absence of an impulse voltage level assigned by the manufacturer.

# Items 2 and 3 were subjected to short-circuit tests with before and after criteria tests and Items 1 and 4 were subjected to power frequency withstand, inter-turn overvoltage and temperature-rise tests.

13 December 2004 to 5 January 2005  
Dates of Tests

M. A. Carstedt  
ASTA Observer

# Record Of Proving Tests

# ASTA

Laboratory Reference No: 101945

## **CLIENT**

Dixson Industrial (s) Pte Ltd  
No.32 Ang Mo Kio Industrial Park 2, #03-12,  
Sing Industrial Complex,  
Singapore 569510

## **DATE OF RECEIPT OF TEST ITEMS**

10 November 2004

## **ORDER NUMBER**

E-mail dated 30/11/2004

## **MANUFACTURER**

The manufacturer has declared that the apparatus was manufactured at the following location:

Dixson Industrial (s) Pte Ltd  
No.32 Ang Mo Kio Industrial Park 2, #03-12,  
Sing Industrial Complex,  
Singapore 569510

13 December 2004 to 5 January 2005  
Dates of Tests

M. A. Carstedt  
ASTA Observer


# Record Of Proving Tests

# ASTA

Laboratory Reference No: 101945

## LABORATORY

The apparatus was tested at:



Testing & Certification Australia  
Lane Cove Testing Station  
18 Mars Road  
Lane Cove NSW 2066 Australia  
Telephone 61 (0)2 9410 5202, Facsimile 61 (0)2 9428 2645

The laboratory accreditation details are:



This laboratory is accredited by the National Association of Testing Authorities, Australia, Accreditation Number 62. The tests reported herein have been performed in accordance with its terms of accreditation.



Quality Management System Certified by NCS International Pty Limited to AS / NZS ISO 9001, Certification Number 12644.



ASTA Accredited Laboratory to ISO / IEC 17025 and ASTA Publication 31, Registration Number 5118.



Quality Management System Certified by ASTA Certification Services to ISO 9001, Registration Number 14063.

13 December 2004 to 5 January 2005  
Dates of Tests

M. A. Carstedt  
ASTA Observer

# Record Of Proving Tests

# ASTA

Laboratory Reference No: 101945

## **SCHEDULE OF TESTS**

| <b>Test</b>  | <b>Page No.</b> |
|--|-----------------|
| Dielectric tests at 100 %                            | 6               |
| Accuracy class tests before short-time current tests | 10              |
| Short-time current tests                             | 7               |
| Assessment after short-time current tests            | 8               |
| Accuracy class tests after short-time current tests  | 10              |
| Temperature-rise tests                               | 11              |

## **TEST CONDITIONS**

### **Short-time current test**

1. Test supply: two phases of a three-phase 50 Hz supply with the supply neutral earthed and the short-circuit point not earthed, see Figure 1.
2. For the short-time current tests on the 2250/5 and 2500/5 CTs the primary conductor consisted of a 2" copper tube having a CSA of approximately 900 mm<sup>2</sup>. No special mounting arrangements were provided with the CTs. The 2250/5 and 2500/5 CTs were mounted on the copper busbar with sheet cork packed between the CT and the copper busbar to centralise the CT and held in place using rope.
3. For the short-time current tests a cable short was placed between the secondary terminals of the CTs.

13 December 2004 to 5 January 2005  
Dates of Tests

M. A. Carstedt  
ASTA Observer

# Record Of Proving Tests

# ASTA

Laboratory Reference No: 101945

## **TEST CONDITIONS (Continued)**

### **Temperature-rise tests**

4. The current transformers were stood on a platform and copper conductors as listed in Table 1 were passed through the centre of the CT window.
5. The secondary windings were connected to unity power factor burdens corresponding to the rated output. A 50 Hz current equal to the rated continuous thermal current was passed through the primary conductor until stable CT secondary winding temperatures were achieved.
6. Copper-constantan thermocouples were used to monitor the surface temperatures of the CT to determine when the CT had attained a stable temperature-rise. (i.e. the variation did not exceed 1 K/h for 1 hour).
7. The ambient temperature was the average of three thermocouples suspended in oil cups with a ½ hour time constant and positioned around the CT at approximately the same height and at a distance of about 1 metre from the CT. The ambient temperature was between 23 °C and 28 °C.
8. The temperature-rise of the windings was measured using the increase in resistance method. (Refer to 11 page for test results).
9. Allowable temperature-rise limits K

|   |    |
|---|----|
| Secondary winding<br>(Class B enamel insulated copper wire)     | 85 |
| Secondary winding inter layer tape<br>(Class B insulating tape) | 85 |
| Surrounding medium<br>(Class B epoxy resin)                     | 85 |

Note: In accordance with Clause 4.6 the maximum allowable temperature-rise is limited to the lowest class of insulation of either the winding or the surrounding medium.

The maximum allowable temperature-rise for the test was 85 K.

**Table 1 – Primary conductor sizes for the temperature-rise tests**

| Item | Ratio  | Class | Rated burden<br>VA | Serial No. | Rated primary current<br>A | Primary Conductor size            |
|------|--------|-------|--------------------|------------|----------------------------|-----------------------------------|
| 1    | 2500/5 | 1     | 30                 | 019742     | 2500                       | 2 - 100 mm x 10 mm copper busbars |
| 4    | 2250/5 | 5P20  | 15                 | 050574     | 2250                       | 2 - 100 mm x 10 mm copper busbars |

13 December 2004 to 5 January 2005  
Dates of Tests

M. A. Carstedt  
ASTA Observer

# Record Of Proving Tests

# ASTA

Laboratory Reference No: 101945

***Power-frequency withstand tests on secondary windings before temperature-rise tests (Clause 8.3 of IEC 60044-1 and BSEN 60044-1)***

Aluminium foil was wrapped around the CTs ( Items 1 and 4) up to within 20 mm from the terminals. A test voltage of 3 kV rms was applied for 1 minute between the short-circuited secondary winding and the aluminium foil.

Result: No puncture or flashovers.

**Date of tests:** 16 December 2004

***Inter-turn overvoltage tests before short-time current tests (Clause 8.4 of IEC 60044-1 and BSEN 60044-1)***

The current transformers withstood tests of inter-turn insulation at the following test voltages applied for 30 seconds using Procedure B of Clause 8.4 at 200 Hz.

Note: Maximum peak voltage of 4.5 kV or rated secondary current which ever is achieved first.

| Item                   | Ratio  | Class            | Rated burden VA | Serial number | Inter-turn overvoltage kV peak for 30 s | Test current A |
|------------------------|--------|------------------|-----------------|---------------|---|----------------|
| 1                      | 2500/5 | 1                | 30              | 019742        | 1.60                                    | 5.0            |
| 4                      | 2250/5 | 5P20             | 15              | 050574        | 4.24                                    | 5.0            |
| <b>Date of tests :</b> |        | 16 December 2004 |                 |               |   |                |

13 December 2004 to 5 January 2005  
Dates of Tests

M. A. Carstedt  
ASTA Observer

# Record Of Proving Tests

# ASTA

Laboratory Reference No: 101945

## Short-time current test (Clause 7.1 of IEC 60044-1 and BSEN 60044-1)

Test at rated short-time thermal current of 63 kA rms for 3 s and rated dynamic current of 158 kA peak

| <b>Condition before test</b>   |                                      |                 |                   |  |          |                                      |
|--|--------------------------------------|-----------------|-------------------|--|----------|--------------------------------------|
| CTs as after the "Criteria tests before short-time withstand test", temperature before test 27 °C                              |                                      |                 |                   |  |          |                                      |
| <b>Item</b>  | <b>Ratio</b>                         | <b>Class</b>    | <b>Serial No.</b> | <b>Test Burden</b>                         |          |                                      |
| 2  | 2500/5                               | 1               | 019743            | Secondary terminals shorted with cables of |          |                                      |
| 3  | 2250/5                               | 5P20            | 050573            | negligible impedance.                      |          |                                      |
|  |                                      |                 |                   |  |          | <b>Diagram Reference</b><br>Figure 1 |
| Photograph No. 24116 B   |                                      |                 |                   |  |          |                                      |
| Test No.   | Test                                 | Applied Voltage | Primary current   |  |          |                                      |
|  |                                      |                 | Asymmetrical      | Symmetrical                                |          | I <sup>2t</sup> equivalent           |
|  |                                      | V rms           | kA peak           | Phase                                      | Duration |                                      |
| 8222.  |                                      |                 |                   | kA rms                                     | s        |                                      |
| 002  | Short-time thermal & dynamic current | 459             | 158               | 69.5                                       | 2.55     | 64.1 kA rms for 3 s                  |
| <b>Observations during test</b>  |                                      |                 |                   |  |          |                                      |
| No visible disturbance.  |                                      |                 |                   |  |          |                                      |
| <b>Condition after test</b>  |                                      |                 |                   |  |          |                                      |
| For condition in accordance with Clause 7.1 of IEC 60044-1 and BSEN 60044-1, requirements a) to d) see pages 8, 9, 10, and 11. |                                      |                 |                   |  |          |                                      |
| <b>Date of test :</b> 14 December 2004   |                                      |                 |                   |  |          |                                      |

13 December 2004 to 5 January 2005  
Dates of Tests

M. A. Carstedt  
ASTA Observer



Laboratory Reference No: 101945

## **Short-time current test (Clause 7.1 of IEC 60044-1 and BSEN 60044-1)**

After the short-time current tests, the current transformers were allowed to cool to ambient temperature (21 °C to 27 °C). They then satisfied the following requirements:

- a) No visible external damage.
- b) The values of current and phase errors did not differ from those recorded before the test by more than half the limits of error appropriate to its accuracy class.  
See page 10.
- c) The current transformers withstood the power frequency withstand test Clause 8.3 and inter-turn over voltage test Clause 8.4 of IEC 60044-1 and BSEN 60044-1 at 90 % of the specified voltages and currents as described on page 9. Dielectric tests to Clause 8.2 are not applicable, as the window-type current transformers do not have a primary conductor or primary insulation.
- d) The current transformers were cut open for inspection. The insulation next to the surface of the secondary conductors showed no deterioration.

See Photographs No. 24116 / L, M, R and S

**Date of inspection:** 5 January 2005

# Record Of Proving Tests

# ASTA

Laboratory Reference No: 101945

### ***Power-frequency withstand tests on secondary windings after short-circuit test (Clause 8.3 of IEC 60044-1 and BSEN 60044-1)***

Aluminium foil was wrapped around the CTs ( items 2 and 3) up to within 20 mm from the terminals. A test voltage of 2.7 kV rms was applied for 1 minute between the short-circuited winding and the aluminium foil.

Result: No puncture or flashovers.

**Date of tests:** 16 December 2004

### ***Inter-turn overvoltage tests after short-circuit test (Clause 8.4 of IEC 60044-1 and BSEN 60044-1)***

The current transformers withstood tests of inter-turn insulation at the following test voltages applied for 30 seconds using Procedure B of Clause 8.4 at 200 Hz.

Note: Maximum peak voltage of 4.05 kV (90% of 4.5 kV) or 4.5 A (90% of rated secondary current) which ever is achieved first.

| Item                   | Ratio  | Class            | Rated burden VA | Serial number | Inter-turn overvoltage kV peak for 30 s | Test current A |
|------------------------|--------|------------------|-----------------|---------------|---|----------------|
| 2                      | 2500/5 | 1                | 30              | 019743        | 1.44                                    | 4.5            |
| 3                      | 2250/5 | 5P20             | 15              | 050573        | 3.68                                    | 4.5            |
| <b>Date of tests :</b> |        | 16 December 2004 |                 |               |   |                |

13 December 2004 to 5 January 2005  
Dates of Tests

M. A. Carstedt  
ASTA Observer

# Record Of Proving Tests

# ASTA

Laboratory Reference No: 101945

## Tests for accuracy (Clause 11.4 of IEC 60044-1 and BSEN 60044-1)

Summary of results before and after short-time current test.

| CT   | % of rated | Burden                     | Before short-time current test |                | After short-time current test |                |
|--|------------|----------------------------|--------------------------------|----------------|-------------------------------|----------------|
|  | current    |                            | Current error %                | Phase error cR | Current error %               | Phase error cR |
| Item 2<br>Ratio : 2500/5<br>Class : 1<br>Serial No. 019743 | 5          | 25%<br>7.5 VA<br>at 0.8 PF | -0.05                          | 0.27           | -0.06                         | 0.29           |
|  | 20         |                            | 0.02                           | 0.16           | 0.01                          | 0.17           |
|  | 100        |                            | 0.06                           | 0.06           | 0.05                          | 0.06           |
|  | 120        |                            | 0.07                           | 0.05           | 0.06                          | 0.05           |
|  | 5          | 100%<br>30 VA<br>at 0.8 PF | -0.41                          | 0.39           | -0.40                         | 0.35           |
|  | 20         |                            | -0.25                          | 0.20           | -0.25                         | 0.17           |
|  | 100        |                            | -0.15                          | 0.04           | -0.12                         | 0.01           |
|  | 120        |                            | -0.18                          | 0.08           | -0.13                         | 0.03           |
| <b>Date of tests :</b>                                     |            |                            | 13 December 2004               |                | 14 December 2004              |                |

## Current error, phase displacement and composite error (Clauses 12.4 and 12.5 of IEC 60044-1 and BSEN 60044-1)

Summary of results before and after short-time current test.

| CT Serial No. (Item 3) | Ratio  | % of rated current | Burden*<br>VA / PF | Before short-time current test |                |                   | After short-time current test |                |                   |
|------------------------|--------|--------------------|--------------------|--------------------------------|----------------|-------------------|-------------------------------|----------------|-------------------|
|                        |        |                    |                    | Current error %                | Phase error cR | Composite error % | Current error %               | Phase error cR | Composite error % |
| 050573                 | 2250/5 | 100                | 15 / 0.8           | 0.41                           | 0.01           | 0.06              | 0.37                          | 0.04           | 0.07              |
| <b>Date of tests :</b> |        |                    |                    | 13 December 2004               |                |                   | 14 December 2004              |                |                   |

\* Note: Composite error calculated using unity power factor for the burden.

13 December 2004 to 5 January 2005  
Dates of Tests

M. A. Carstedt  
ASTA Observer

# Record Of Proving Tests

# ASTA

Laboratory Reference No: 101945

## *Temperature-rise tests (Clause 7.2 of IEC 60044-1 and BSEN 60044-1)*

### Test Results

| Item | Ratio  | Class | Rated burden<br>VA | Serial No. | Rated primary current<br>A | Temperature-rise<br>K (allowable) |
|------|--------|-------|--------------------|------------|----------------------------|-----------------------------------|
| 1    | 2500/5 | 1     | 30                 | 019742     | 2500                       | 18.9 85                           |
| 4    | 2250/5 | 5P20  | 15                 | 050574     | 2250                       | 23.1 85                           |

**Date of tests :** 17 and 20 December 2004

See Photograph No. 24116 H

## **PHOTOGRAPHS**

### **Number          Caption**

24116 /

- B      Short-circuit test set-up before Test 8222.002
- H      Temperature-rise set up of 2250/5 A current transformer
- L      Typical label for 2500/5 A current transformer
- M      Typical label for 2250/5 A current transformer
- R      2500/5 A current transformer
- S      2250/5 A current transformer

13 December 2004 to 5 January 2005  
Dates of Tests

M. A. Carstedt  
ASTA Observer

# Record Of Proving Tests

# ASTA

Laboratory Reference No: 101945






FIGURE 1 Test Circuit Diagram

M. A. Carstedt  
ASTA Observer

Current  
200.0 kA/ Div




Voltage  
100.0 V/ Div




Testing &  
Certification  
Australia

OSC. No. : 8222.002

Current  
200.0 kA/ Div



Voltage  
100.0 V/ Div




1400.0 1600.0 1800.0 2000.0 2200.0 2400.0 2600.0 2800.0  
Time : milli-seconds



Testing &  
Certification  
Australia


OSC. No. : 8222.002



Manufacturer: DIXSON INDUSTRIAL (S) PTE LTD  
 Address: NO.32 Ang Mo kio Industrial Park 2  
 Sing Industrial Complex, #03-12.  
 SINGAPORE 569510  
 TEL/FAX: +65 64812240 / 64811371

Number of turns for CT: 450 Turns.  
 Materials: Diameter 1.6mm enamelled copper wire.  
 Epoxy for coating steel core-5700 Epoxy Power Coating.  
 Epoxy for final coating-Mixture of Casting Resin 5957A and  
 Curing Agent 5957B.  
 Steel core-0.27mm Thick Silicon Steel.

Two layers of winding. The 1st layer is coated in epoxy  
 and wrapped with PVC tape of thickness 0.15mm with  
 insulation class B, winding is then fully coated  
 in epoxy.



I Frank Lin Of Dixon Industrial (S) Pte Ltd  
 Certify that this drawing is a true representation  
 of the apparatus tested.


*Frank Lin*

|   |                           |
|---|---------------------------|
| TITLE: NITECH 2250/5 Class5P20 15VA Current Transformer | DRAWN BY: Mr Frank Lin    |
| DRAWING NUMBER: 2250/5 1 OF 2                           | APPROVED BY: Mr Peter Lin |
| DATE ISSUED: 25 OCT 2004                                |                           |



I Mr Frank Lin of Dixon Industrial (S) Pte Ltd certify that this drawing is a true representation of the apparatus tested.

*Frank*




TOP VIEW  
Scale 1:2

PLAN VIEW  
Scale 1:2

TESTING &  
CERTIFICATION AUSTRALIA  
LABORATORY REFERENCE No. 101045  
This drawing/schedule applies to the apparatus tested.  
*M.A. Centell* 18/1/05  
Signature on behalf of the Testing Authority. Date

SIDE VIEW  
Scale 1:2

|   |                           |
|---|---------------------------|
| TITLE: NITECH 2250/5 Class5p20 15VA Current Transformer | DRAWN BY: Mr Frank Lin    |
| DRAWING NUMBER: 2250/5 2 OF 2                           | APPROVED BY: Mr Peter Lin |
| DATE ISSUED: 25 OCT 2004                                |                           |



Manufacturer: DIXSON INDUSTRIAL (S) PTE LTD  
 Address: NO.32 Ang Mo Kio Industrial Park 2,  
 Sing Industrial Complex, #03-12.  
 SINGAPORE 569510  
 TEL./FAX: +65 64812240 / 64811371

Number of turns for CT: 500 Turns.  
 Materials: Diameter 1.6mm enamelled copper wire.  
 Epoxy for coating steel core--5700 Epoxy Power Coating.  
 Epoxy for final coating--Mixture of Casting Resin 5957A and  
 Curing Agent 5957B.  
 Steel core--0.27mm Thick Silicon Steel.  
 Two layers of winding. The 1st layer is coated in epoxy and  
 wrapped with PVC tape of thickness 0.15mm with insulation  
 class B, winding is then fully coated in epoxy.

TESTING &  
 CERTIFICATION AUSTRALIA  
 LABORATORY REFERENCE No. 101945  
 This drawing/rectitude applies to the apparatus tested.  
 M.A. Contell 18/1/05  
 Signature on behalf of the Testing Authority. Date

I Frank Lin Of Dixson Industrial (S) Pte Ltd  
 Certify that this drawing is a true representation  
 of the apparatus tested.

*Frank Lin*

SECTION A-A

Scale 2:1

TITLE: NITECH 2500/5 Class1 30VA Current Transformer

DRAWN BY: Mr Frank Lin


DRAWING NUMBER: 2500/5 1 OF 2

DATE ISSUED: 25 OCT 2004


APPROVED BY: Mr Peter Lin

I Mr Frank of Dixon Industrial (S) Pte Ltd  
 certify that this drawing is a true representation  
 of the apparatus tested.


*Frank*



TOP VIEW  
 Scale 1:2



PLAN VIEW  
 Scale 1:2



SIDE VIEW  
 Scale 1:2

TESTING &  
 CERTIFICATION AUSTRALIA  
 LABORATORY REFERENCE No. 10194S  
 This drawing/schedule applies to the apparatus tested.  
*M.A. Centell* 19/10/05  
 Signature on behalf of the Testing Authority. Date

TITLE: NITECH 2500/5 Class1 30VA Current Transformer  
 DRAWN BY: Mr Frank Lin  
 DATE ISSUED: 25 OCT 2004  
 APPROVED BY: Mr Peter Lin